

**RAPORT DE INCERCARE nr. / data emiterii: PT0215698 / 06-08-2021**
**Nume client: EURO APAVOL SA / STR. GHEORGHE DINCA, SERG. nr. 19 A- 19B-19C VOLUNTARI**
**Provenienta probei: proba apa potabila**
**Adresa prelevare: Str. Sinaia, Com. Stefanestii de Jos - lesire bazin GA2**
**Data prelevării probei - ora prelevare: 03-08-2021 08:00**
**Data primirii probei / data efectuării analizelor: 03-08-2021 10:45 / 03-08-2021 - 06-08-2021**
**Cine a recoltat proba: CLIENT EXTERN**
**I.DETERMINARI FIZICO-CHIMICE**

Nr. crt.	Indicatori organoleptici si fizico-chimici	Unitate de masura	Valori obtinute	Valori maxim admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Miros*	-	Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN 1622: 2007
2	Culoare*	grade / nm pH/Temp.(°C)	1 / 455 7.82/21.3 Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN ISO 7887: 2012
3	pH	pH/Temp.(°C)	7.82/21.3	≈6.5; ≈9.5	SR EN ISO 10523:2012
4	Conductivitate	µS/cm la 25°C	687	2500	SR EN 27888:1997
5	Amoniu	mg/l	0.407	0.50	SR ISO 7150-1:2001
6	Nitriti	mg/l	<0.033	0.50	SR EN 26777:2002 SR EN 26777:2002/C91:2006
7	Nitrati	mg/l	0.398	50	SR ISO 7890-3:2000
8	Fier	µg/l	94	200	SR ISO 6332:1996 SR ISO 6332:1996/C91:2006
9	Duritate totala	grade germane	7.55	≥ 5	SR ISO 6059:2008
10	Aluminiu	µg/l	<10	200	SR ISO 10566:2001
11	Oxidabilitate (metoda indicelui de permanganat)	mgO <sub>2</sub> /l	1.13	5.0	SR EN ISO 8467:2001
12	Clor rezidual liber	mg/l	<0.03*	≥0.10; ≤0.50	SR EN ISO 7393-2:2018
13	Turbiditate	NTU	0.250	≤ 5.0	SR EN ISO 7027-1:2016

\*2 h:45 min - reprezinta diferenta de timp intre prelevare si analiza; maxim 6 ore

**II.DETERMINARI MICROBIOLOGICE**

Nr. crt.	Indicatori microbiologici	Unitate de masura	Valori obtinute	Valori admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
2	Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
3	Enterococi	UFC/100 ml	0	0	SR EN ISO 7899 - 2 : 2002
4	Numar de colonii la 22° C	UFC/ml	0	Nici o modificare anormala	SR EN ISO 6222:2004
5	Numar de colonii la 37° C	UFC/ml	1	Nici o modificare anormala	SR EN ISO 6222:2004

\*Nota: Apa netratata. Nici o modificare anormala: nr. de colonii la 37°C/22°C &lt; de 300 UFC/ml.


Apa tratata. Nici o modificare anormala: nr. de colonii la 37°C &lt; 20 UFC/ml.

nr. de colonii la 22°C &lt; 100 UFC/ml.

Informatiile privind prelevarea probei se regasesc in Formularul de receptie PT0215698 / 03-08-2021

 Verificat / Aprobat / Sef laborator  
 Nicoleta Ramaressi

 Intocmit inginer chimist  
 Iulian Vasiliu

 Intocmit biolog  
 Florina Mandache


Rezultatele incercarilor se refera numai la proba de apa analizata. Proba de apa are caracter momentan.

Proba se preleveaza conform procedurii generale cod: LCCAP - PG 7.3.

Raportul de incercare se completeaza in doua exemplare.

\* Incercare neacreditata.

Document privat, emis de Apa Nova Bucuresti SA, contine date cu caracter personal © - a nu se difuza neautorizat in extern.

Reproducerea partiala este interzisa fara acordul laboratorului.

Cod LCCAP - F 7.8.1/Rev.2/03.2020.

Rezultatele notate "&lt;" reprezinta valori situate sub limita de cuantificare a metodei. CMA: concentratia maxima admisa.

**RAPORT DE INCERCARE nr. / data emiterii: PT0215699 / 06-08-2021**
**Nume client: EURO APAVOL SA / STR. GHEORGHE DINCA, SERG. nr. 19 A- 19B-19C VOLUNTARI**
**Provenienta probei: proba apa potabila**
**Adresa prelevare: Str. Stanjenilor, Com. Stefanestii de Jos - lesire bazin GA1**
**Data prelevării probei - ora prelevare: 03-08-2021 08:15**
**Data primirii probei / data efectuării analizelor: 03-08-2021 10:47 / 03-08-2021 - 06-08-2021**
**Cine a recoltat proba: CLIENT EXTERN**
**I.DETERMINARI FIZICO-CHIMICE**

Nr. crt.	Indicatori organoleptici si fizico-chimici	Unitate de masura	Valori obtinute	Valori maxim admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Miros*	-	Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN 1622: 2007
2	Culoare*	grade / nm pH/Temp.(°C)	1 / 455 7.85/21.4 Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN ISO 7887: 2012
3	pH	pH/Temp.(°C)	7.85/21.4	≥6.5; ≤9.5	SR EN ISO 10523:2012
4	Conductivitate	µS/cm la 25°C	702	2500	SR EN 27888:1997
5	Amoniu	mg/l	0.432	0.50	SR ISO 7150-1:2001
6	Nitriti	mg/l	<0.033	0.50	SR EN 26777:2002 SR EN 26777:2002/C91:2006
7	Nitrati	mg/l	0.437	50	SR ISO 7890-3:2000
8	Fier	µg/l	91	200	SR ISO 6332:1996 SR ISO 6332:1996/C91:2006
9	Duritate totala	grade germane	7.22	≥ 5	SR ISO 6059:2008
10	Aluminiu	µg/l	<10	200	SR ISO 10566:2001
11	Oxidabilitate (metoda indicelui de permanganat)	mgO2/l	1.26	5.0	SR EN ISO 8467:2001
12	Clor rezidual liber	mg/l	<0.03 <sup>1</sup>	≥0.10; ≤0.50	SR EN ISO 7393-2:2018
13	Turbiditate	NTU	0.355	≤ 5.0	SR EN ISO 7027-1:2016

\*2 h:32 min - reprezinta diferenta de timp intre prelevare si analiza; maxim 6 ore

**II.DETERMINARI MICROBIOLOGICE**

Nr. crt.	Indicatori microbiologici	Unitate de masura	Valori obtinute	Valori admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
2	Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
3	Enterococi	UFC/100 ml	0	0	SR EN ISO 7899 - 2 : 2002
4	Numar de colonii la 22° C	UFC/ml	0	Nici o modificare anormala	SR EN ISO 6222:2004
5	Numar de colonii la 37° C	UFC/ml	1	Nici o modificare anormala	SR EN ISO 6222:2004

\*Nota: Apa netratata. Nici o modificare anormala: nr. de colonii la 37°C/22°C &lt; de 300 UFC/ml.

Apa tratata. Nici o modificare anormala: nr. de colonii la 37°C &lt; 20 UFC/ml.

nr. de colonii la 22°C &lt; 100 UFC/ml.

Informatiile privind prelevarea probei se regasesc in Formularul de receptie PT0215699 / 03-08-2021

 Verificat / Aprobat / Sef laborator  
 Nicoleta Ramiresi

 Intocmit inginer chimist  
 Iulian Vasiliu

 Intocmit biolog  
 Florina Mandache






 Rezultatele incercarilor se refera numai la proba de apa analizata, Proba de apa are caracter momentan.  
 Proba se preleveaza conform procedurii generale cod: LCCAP – PG 7.3.

Raportul de incercare se completeaza in doua exemplare.

\* Incercare neacreditata.

 Document privat, emis de Apa Nova Bucuresti SA, contine date cu caracter personal © – a nu se difuza neautorizat in extern.  
 Reproducerea partiala este interzisa fara acordul laboratorului.

Cod LCCAP – F 7.8.1/Rev.2/03.2020.

Rezultatele notate "&lt;" reprezinta valori situate sub limita de cuantificare a metodei. CMA: concentratia maxima admisa.



**RAPORT DE INCERCARE nr. / data emiterii: PT0215700 / 06-08-2021**
**Nume client: EURO APAVOL SA / STR. GHEORGHE DINCA, SERG. nr. 19 A- 19B-19C VOLUNTARI**
**Provenienta probei: proba apa potabila**
**Adresa prelevare: Str. Rozelor, Com. Stefanestii de Jos - cismea**
**Data prelevării probei - ora prelevare: 03-08-2021 08:30**
**Data primirii probei / data efectuării analizelor: 03-08-2021 10:48 / 03-08-2021 - 06-08-2021**
**Cine a recoltat proba: CLIENT EXTERN**
**I.DETERMINARI FIZICO-CHIMICE**

Nr. crt.	Indicatori organoleptici si fizico-chimici	Unitate de masura	Valori obtinute	Valori maxim admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Miros*	-	Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN 1622: 2007
2	Culoare*	grade / nm pH/Temp.(°C)	1 / 455 7.82/21.2 Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN ISO 7887: 2012
3	pH	pH/Temp.(°C)	7.82/21.2	≥6.5; ≤9.5	SR EN ISO 10523:2012
4	Conductivitate	µS/cm la 25°C	690	2500	SR EN 27888:1997
5	Amoniu	mg/l	0.431	0.50	SR ISO 7150-1:2001
6	Nitriti	mg/l	<0.033	0.50	SR EN 26777:2002 SR EN 26777:2002/C91:2006
7	Nitrati	mg/l	0.438	50	SR ISO 7890-3:2000
8	Fier	µg/l	85	200	SR ISO 6332:1996 SR ISO 6332:1996/C91:2006
9	Duritate totala	grade germane	7.33	≥ 5	SR ISO 6059:2008
10	Aluminiu	µg/l	<10	200	SR ISO 10566:2001
11	Oxidabilitate (metoda indicelui de permanganat)	mgO2/l	1.38	5.0	SR EN ISO 8467:2001
12	Clor rezidual liber	mg/l	<0.03 <sup>1</sup>	≥0.10; ≤0.50	SR EN ISO 7393-2:2018
13	Turbiditate	NTU	0.211	≤ 5.0	SR EN ISO 7027-1:2016

**\*2 h:18 min - reprezinta diferenta de timp intre prelevare si analiza; maxim 6 ore**
**II.DETERMINARI MICROBIOLOGICE**

Nr. crt.	Indicatori microbiologici	Unitate de masura	Valori obtinute	Valori admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
2	Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
3	Enterococi	UFC/100 ml	0	0	SR EN ISO 7899 - 2 : 2002
4	Numar de colonii la 22° C	UFC/ml	1	Nici o modificare anormala	SR EN ISO 6222:2004
5	Numar de colonii la 37° C	UFC/ml	0	Nici o modificare anormala	SR EN ISO 6222:2004

**\*Nota: Apa netratata. Nici o modificare anormala: nr. de colonii la 37°C/22°C < de 300 UFC/ml.**
**Apa tratata. Nici o modificare anormala: nr. de colonii la 37°C < 20 UFC/ml.**
**nr. de colonii la 22°C < 100 UFC/ml.**
**Informatiile privind prelevarea probei se regasesc in Formularul de receptie PT0215700 / 03-08-2021**
**Verificat / Aprobat / Sef laborator**  
 Nicoleta Ramiresi

**Intocmit inginer chimist**  
 Iulian Vasiliu

**Intocmit biolog**  
 Florina Mandache






Rezultatele incercarilor se refera numai la proba de apa analizata. Proba de apa are caracter momentan.

Proba se preleveaza conform procedurii generale cod: LCCAP - PG 7.3.

Raportul de incercare se completeaza in doua exemplare.

\* Incercare neacreditata.

Document privat, emisa de Apa Nova Bucuresti SA, contine date cu caracter personal © - a nu se difuza neautorizat in extern.

Reproducerea partiala este interzisa fara acordul laboratorului.

Cod LCCAP - F 7.8.1/Rev.2/03.2020.

Rezultatele notate "&lt;" reprezinta valori situate sub limita de cuantificare a metodei. CMA: concentratia maxima admisa.

**RAPORT DE INCERCARE nr. / data emiterii: PT0215701 / 06-08-2021**

Nume client: EURO APAVOL SA / STR. GHEORGHE DINCA, SERG. nr. 19 A- 19B-19C VOLUNTARI

Provenienta probei: proba apa potabila

Adresa prelevare: Str. Cernei nr.8, Com. Stefanesti de Jos - Camin de batrani

Data prelevării probei - ora prelevare: 03-08-2021 08:45

Data primirii probei / data efectuării analizelor: 03-08-2021 10:49 / 03-08-2021 - 06-08-2021

Cine a recoltat proba: CLIENT EXTERN

**I.DETERMINARI FIZICO-CHEMICE**

Nr. crt.	Indicatori organoleptici si fizico-chimici	Unitate de masura	Valori obtinute	Valori maxim admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Miros*	-	Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN 1622: 2007
2	Culoare*	grade / nm pH/Temp.(°C)	1 / 455 7.79/21.1 Acceptabila	Acceptabila consumatorilor si nici o modificare anormala	SR EN ISO 7887: 2012
3	pH	pH/Temp.(°C)	7.79/21.1	≥6.5; ≤9.5	SR EN ISO 10523:2012
4	Conductivitate	µS/cm la 25°C	686	2500	SR EN 27888:1997
5	Amoniu	mg/l	0.406	0.50	SR ISO 7150-1:2001
6	Nitriti	mg/l	<0.033	0.50	SR EN 26777:2002 SR EN 26777:2002/C91:2006
7	Nitrati	mg/l	0.447	50	SR ISO 7890-3:2000
8	Fier	µg/l	83	200	SR ISO 6332:1996 SR ISO 6332:1996/C91:2006
9	Duritate totala	grade germane	7.55	≥ 5	SR ISO 6059:2008
10	Aluminiu	µg/l	<10	200	SR ISO 10566:2001
11	Oxidabilitate (metoda indicelui de permanganat)	mgO2/l	1.13	5.0	SR EN ISO 8467:2001
12	Clor rezidual liber	mg/l	<0.03 <sup>1</sup>	≥0.10; ≤0.50	SR EN ISO 7393-2:2018
13	Turbiditate	NTU	0.242	≤ 5,0	SR EN ISO 7027-1:2016

\*2 h:04 min - reprezinta diferenta de timp intre prelevare si analiza; maxim 6 ore

**II.DETERMINARI MICROBIOLOGICE**

Nr. crt.	Indicatori microbiologici	Unitate de masura	Valori obtinute	Valori admise (conf.L. 458/2002 cu modificarile ulterioare)	Referential
1	Bacterii coliforme	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
2	Escherichia coli	UFC/100 ml	0	0	SR EN ISO 9308-1: 2015 SR EN ISO 9308-1: 2015/A1:2017
3	Enterococi	UFC/100 ml	0	0	SR EN ISO 7899 - 2 : 2002
4	Numar de colonii la 22° C	UFC/ml	0	Nici o modificare anormala	SR EN ISO 6222:2004
5	Numar de colonii la 37° C	UFC/ml	0	Nici o modificare anormala	SR EN ISO 6222:2004

\*Nota: Apa netratata. Nici o modificare anormala: nr. de colonii la 37°C/22°C &lt; de 300 UFC/ml.

Apa tratata. Nici o modificare anormala: nr. de colonii la 37°C &lt; 20 UFC/ml.

nr. de colonii la 22°C &lt; 100 UFC/ml.

Informatiile privind prelevarea probei se regasesc in Formularul de receptie PT0215701 / 03-08-2021

 Verificat / Aprobat / Sef laborator  
 Nicoleta Ramaressi

 Intocmit inginer chimist  
 Iulian Vasiliu

 Intocmit biolog  
 Florina Mandache






Rezultatele incercarilor se refera numai la proba de apa analizata. Proba de apa are caracter momentan.

Proba se preleveaza conform procedurii generale cod: LCCAP - PG 7.3.

Raportul de incercare se completeaza in doua exemplare.

\* Incercare neacreditata.

Document privat, emis de Apa Nova Bucuresti SA, contine date cu caracter personal © - a nu se difuza neautorizat in extern.

Reproducerea partiala este interzisa fara acordul laboratorului.

Cod LCCAP - F 7.8.1/Rev.2/03.2020.

Rezultatele notate "&lt;" reprezinta valori situate sub limita de cuantificare a metodei. CMA: concentratia maxima admisa.