

Buletin de analiza nr. 1568A-1570A din 14.09.2021

Probe prelevate de la: S.C. EURO APAVOL S.A. VOLUNTARI-STATIA DE APA SINESTI
 Denumire proba : Proba apa Iesire statie; Proba apa retea

Prezentate la analiza de: Dr. Ungureanu S.

La data de 07.09.2021 cu procesul verbal nr. 1472/07.09.2021


Data efectuării analizei: 07.09.2021 - 09.09.2021

Informatii referitoare la proba(e): Probe recoltate in recipienti sterili de 500ml cu adaos de 0,5 ml tiosulfat de sodium 5%.

Analize microbiologice efectuate conform: SR EN ISO 6222/2004; SR EN ISO 9308-1/2015; SR EN ISO 9308-1/A1/2017; SR EN ISO 7899-2/2002.

REZULTATE

Cod proba	Tipul probei <input checked="" type="checkbox"/> Iesire <input checked="" type="checkbox"/> Apa retea <input type="checkbox"/> Put forat	Numar de colonii la 22°C UFC/ ml	Numar de colonii la 37 °C UFC/ ml	Bacterii coliforme UFC/ 100 ml	E.coli UFC / 100 ml	Enterococi UFC/ 100 ml
1568A	Proba apa- Iesire statie	/	/	/	0	0
1569A	Proba apa retea-Scoala Sinesti	/	/	/	0	0
1570A	Proba apa retea –Gradinita Sinesti	/	/	/	0	0
	Valori normale cf. Legii 458/2002 modificata si completata prin Ordonanta nr.22/2017	Nici o modificare anormala	Nici o modificare anormala	0/100ml	0/100ml	0/100ml
DECIZIE	Conform Legii 458/2002 modificata si completata prin Ordonanta nr.22/2017	Toti parametrii analizati corespund				

Analize efectuate de: Executant :
 As. 

Responsabil de analiza
 Biolog pr.


 Iosif Mariana
 -biolog medical-
 Cod 435617

Sef laborator
 Dr. Dobre Georgeta
 Medic primar
 Dr. in Stiinte Medicale


 Dr. DOBRE GEORGETA
 Medic primar laborator
 Doctor in stiinte medicale
 COD 259131

Rezultatele se refera numai la probele analizate
 Buletinul nu poate fi reprodus decit integral fara aprobarea laboratorului
 Cod BA-B-18-01A

Exemplar 1 din 2
 Pagina 1 din 1